2012 Air Emissions Testing FAQs

Q: What is the purpose of annual air emissions stack testing?

A: Stack testing is an important tool that measures the amount of regulated pollutants being emitted from a facility. Stack testing consists of a series of sampling events, in which a probe is inserted into the stack gases to collect a representative sample, over a defined amount of time. Sampling and subsequent laboratory analysis must be conducted in accordance with New York State Department of Environmental Conservation (NYSDEC) and United States Environmental Protection Agency (USEPA) protocols. NYSDEC oversees stack testing at the Onondaga County Waste-to-Energy (WTE) Facility.

Q: How do the 2012 stack test results look?

A: The results from the 2012 stack testing look good! They indicate that **the Facility is being well operated** and that the **air pollution control devices are functioning properly**. As shown by the summary graph, many of the parameters were significantly below the permit limits.

Q: Does the Facility conduct any other air emissions testing besides the annual stack testing?

A: Yes. The Facility has a continuous emission monitoring system (CEMS) that measures equipment performance and stack emissions. The CEMS monitors carbon monoxide, carbon dioxide, oxygen, sulfur dioxide, and nitrogen oxides (NOx) as well as opacity and combustion temperatures.

Q: What is the status of the Facility Air (Title V) Permit?

A: **NYSDEC** renewed the Facility Air Permit, effective August 8, 2011 through August 7, 2016. The permit can be **accessed on NYSDEC**'s **website** at the following webpage: http://www.dec.ny.gov/dardata/boss/afs/permits/731420002800009_r1.pdf.

Q: Who can I contact for more information?

A: For more detailed information on the test results please contact OCRRA's Agency Engineer, Amy Miller, at **453.2866** or **amiller@ocrra.org**. For additional questions of OCRRA's Public Information Officer, please contact Kristen Lawton at **295.0733** or **klawton@ocrra.org**.

2012 ANNUAL STACK TEST RESULTS

| | | Average Measured Em | | issions ¹ | Permit | Pass/Fail? | |
|------------|---------|--|----------|----------------------|------------|--------------------|-----|
| | | Constituent | Unit 1 | Unit 2 | Unit 3 | Limit ² | P/F |
| | | Cadmium (mg/dscm @ 7% O ₂) ³ | 3.66E-04 | < 1.86E-04 | < 2.23E-04 | 3.50E-02 | Р |
| | | Cadmium (lb/hr) ³ | 5.51E-05 | < 2.89E-05 | < 3.64E-05 | 1.90E-03 | Р |
| | | Carbon Monoxide (lb/hr) | 1.24E+00 | 9.99E-01 | 1.24E+00 | 8.04E+00 | Р |
| | | Dioxins/Furans (ng/dscm @ 7% O ₂) | 8.99E-01 | 3.34E-01 | 6.04E-01 | 3.00E+01 | Р |
| | | Hydrogen Chloride (ppmdv @ 7% O ₂) | 3.32E+00 | 1.16E+00 | 3.78E+00 | 2.50E+01 | Р |
| | L | Hydrogen Chloride (lb/hr) | 7.83E-01 | 2.69E-01 | 9.43E-01 | 5.24E+00 | Р |
| | ۲ | Hydrogen Chloride Removal Efficiency (%) | 99.6 | 99.8 | 99.6 | >=95 | Р |
| ≻ | Ä | Lead (mg/dscm @ 7% O ₂) ³ | 5.09E-03 | 1.24E-03 | 1.88E-03 | 4.00E-01 | Р |
| ۱₩ | FEDERAL | Lead (lb/hr) ³ | 7.66E-04 | 1.94E-04 | 3.07E-04 | 3.81E-02 | Р |
| ANNUALLY | | Mercury (lb/hr) | 6.79E-04 | 2.33E-04 | 6.81E-04 | 4.00E-03 | Р |
| | | Nitrogen Oxides (lb/hr) | 4.97E+01 | 5.39E+01 | 5.66E+01 | 5.80E+01 | Р |
| | | Particulates (gr/dscf @ 7% O ₂) | 7.12E-04 | 6.48E-04 | 6.92E-04 | 1.00E-02 | Р |
| STED | | PM ₁₀ (gr/dscf @ 7% O ₂) | 5.63E-04 | 3.15E-04 | 3.00E-04 | 1.00E-02 | Р |
| S | | PM ₁₀ (lb/hr) | 1.94E-01 | 1.09E-01 | 1.10E-01 | 3.16E+00 | Р |
| 빝 | | Sulfur Dioxide (lb/hr) | 6.05E+00 | 4.99E-01 | 4.86E+00 | 1.62E+01 | Р |
| | STATE | Ammonia (ppmdv @ 7% O ₂) | 4.83E+00 | 3.19E+00 | < 1.01E+00 | 5.00E+01 | Р |
| | | Ammonia (lb/hr) | 5.41E-01 | 3.45E-01 | < 1.18E-01 | 4.88E+00 | Р |
| | | Dioxins/Furans-2,3,7,8 TCDD TEQ (ng/dscm @ 7% O ₂) | 1.40E-02 | 4.75E-03 | 1.01E-02 | 4.00E-01 | Р |
| | | Dioxins/Furans-2,3,7,8 TCDD TEQ (lb/hr) | 2.14E-09 | 7.64E-10 | 1.62E-09 | 1.29E-07 | Р |
| | | Mercury (μg/dscm @ 7% O ₂) | 4.56E+00 | 1.50E+00 | 4.19E+00 | 2.80E+01 | Р |
| | | Mercury Removal Efficiency (%) | 94.9 | 98.8 | 95.2 | >=85 | Р |
| | | Zinc (lb/hr) ³ | 4.58E-03 | 3.00E-03 | 6.06E-03 | 1.42E-01 | Р |

NOTES:

UNITS:

gr/dscf = grains per dry standard cubic foot

ppmdv = parts per million dry volume

lb/hr = pounds per hour

ng/dscm = nanograms per dry standard cubic meter

μg/dscm = microgramsper dry standard cubic meter

mg/dscm = milligrams per dry standard cubic meter

@ $7\% O_2$ = concentration corrected to 7% oxygen


Last Revised: 8/9/2012, AKL

¹ Based on three test runs


² NYSDEC Title V Permit #7-3142-00028/00009

³ Unit #1 results are based on June retesting event

Comparison of Long-Term Facility Average to 2012 Test Results (Average of 3 Boiler Units)



Facility Mercury Emissions & Air Pollution Control System Effectiveness



2012 Ash Testing FAQs

Q: What is the purpose of the semi-annual ash testing and how do the 2012 results look?

A: A representative sample of combined bottom and fly ash is collected according to NYSDEC protocols. This sample is then analyzed by an independent laboratory for leachable metals, according to EPA's Toxicity Characteristic Leaching Procedure (TCLP). TCLP analysis simulates landfill conditions (the final disposal site for the ash) and determines whether the ash exhibits hazardous characteristics. Over the life of the facility (including the most recent 2012 results), TCLP analysis has always indicated that the ash is non-hazardous.

Q: Who can I contact for more information?

A: For more detailed information on the test results please contact OCRRA's Agency Engineer, Amy Miller, at **453.2866** or **amiller@ocrra.org**. For additional questions of OCRRA's Public Information Officer, please contact Kristen Lawton at **295.0733** or **klawton@ocrra.org**.

2012 ASH RESIDUE CHARACTERIZATION TEST RESULTS

<u>Semi-Annual Test Results - June 2012</u>

| Constituent | Test Result | Permit Limit | Pass or Fail |
|-------------|-------------|--------------|--------------|
| Cadmium | 0.28 mg/L | 1 mg/L | Pass |
| Lead | 0.50 mg/L | 5 mg/L | Pass |

Semi-Annual Test Results - Sept/Oct 2012

| Constituent | Test Result | Permit Limit | Pass or Fail |
|-------------|-------------|--------------|--------------|
| Cadmium | 0.61 mg/L | 1 mg/L | Pass |
| Lead | 0.57 mg/L | 5 mg/L | Pass |

CONCLUSION

Ash residue does NOT exhibit a hazardous characteristic. As such, it should continue to be managed as a non-hazardous solid waste.